



RELATÓRIO DOS PARAMETROS PARA CONTA DE ÁGUA DO CONSUMIDOR - Decreto nº 5.440 de 04.05.2005

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	CENTRO, JANGADÃO, HOSPITAL, MANAIM SETOR I -	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	0,82	0,75	5,97	0,56	5,12	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	ORIENTE MEDIO DE EXTREMOZ, MALVINAS, NOVO HORIZONTE - SETOR II	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	0,40	0,75	5,13	1,44	1,06	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	ESTRELA DO MAR, PASSAGEM DA VILA - SETOR III	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	0,26	0,75	5,51	0,10	1,38	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	CONJUNTO ALTO EXTREMOZ, LINHA FÉRREA E BOSQUE DE EXTREMOZ - SETOR - IV	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	1,20	0,75	6,12	0,27	0,66	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	JARDINS DE EXTREMOZ, BROGODÓ E SÃO MIGUEL ARCANJO - SETOR V	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	1,00	0,75	4,75	0,88	4,89	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	PASSAGEM DA VILA - SETOR VI	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	0,77	0,75	4,25	0,70	3,97	100%

REFERENCIA DO POÇO		RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
	POTIGUAR, ALAMEDAS E COSTAS DAS DUNAS - SETOR VII	VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
	MÉDIA DOS CONJUNTOS E LOTEAMENTOS	1,94	0,75	5,18	0,50	1,66	100%

REFERENCIA DO POÇO	NOVO AMERICA, KM23 E CASTANYERO - SETOR VIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,22	0,75	4,70	2,43	2,30	100%
REFERENCIA DO POÇO	CHACARÁS DE EXTREMOZ - SETOR VX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,55	0,75	4,59	3,25	0,67	100%
REFERENCIA DO POÇO	QUINTAS DAS FIGUEIRAS, RIVIEIRA, ITALIA E VILA MARIA - SETOR X	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,01	0,93	4,59	2,66	2,20	100%
REFERENCIA DO POÇO	MOINHO DOS VENTOS - SETOR XI	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,10	0,82	3,81	0,64	3,38	96%
REFERENCIA DO POÇO	CENTRAL PARQUE CLUBES - SETOR XII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		2,47	0,75	3,72	0,43	2,22	100%
REFERENCIA DO POÇO	PARQUE DO SERVIDOR - SETOR XIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,23	0,75	5,17	0,55	1,68	75%
REFERENCIA DO POÇO	ESTIVAS E ALTO DE ESTIVAS - SETOR VX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		2,65	0,75	4,51	0,38	3,11	95%

REFERENCIA DO POÇO	SANTO AMARO, CARÃO E VENUS - SETOR XV	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,22	0,75	5,76	2,07	3,98	100%
REFERENCIA DO POÇO	MOINHO - SETOR XVI	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		2,37	0,75	4,98	1,20	2,18	100%
REFERENCIA DO POÇO	PARQUE DAS JAQUEIRAS - SETOR XVII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,47	0,75	4,15	0,10	2,71	100%
REFERENCIA DO POÇO	SANTOS DRUMMONT - SETOR XVIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,51	0,75	4,87	0,20	10,28	100%
REFERENCIA DO POÇO	COMUM - SETOR VX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,34	0,75	4,84	1,10	1,94	100%
REFERENCIA DO POÇO	CAPIM - SETOR XX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,49	0,75	5,04	0,95	5,12	100%
REFERENCIA DO POÇO	ARAÇA - SETOR XXI	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		2,01	#DIV/0!	7,80	0,70	2,71	100%
REFERENCIA DO POÇO	CONTENDAS - SETOR XXII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,28	0,75	4,89	1,00	7,77	95%
REFERENCIA DO POÇO	PRAIA DE PITANGUI - SETOR XXIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,33	0,75	5,23	0,61	3,25	99%
REFERENCIA DO POÇO	PRAIA DE GENIPABÚ - SETOR XXIV	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,33	0,75	5,94	0,87	1,97	100%
REFERENCIA DO POÇO	PRAIA DE SANTA RITA - SETOR XXV	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,62	0,75	5,24	1,40	1,86	100%
REFERENCIA DO POÇO	CAMPINAS - SETOR XXVI	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,68	0,75	5,57	0,70	8,05	100%
REFERENCIA DO POÇO	PORTAL DO SOL - SETOR XXVII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,44	0,75	5,26	0,90	7,96	100%

REFERENCIA DO POÇO	BOCA DA ILHA, PEDRINHAS E GRUTAS - SETOR XXVIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,15	0,75	5,52	1,93	10,39	100%
REFERENCIA DO POÇO	MURICI - SETOR XXVX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,72	0,75	6,51	0,45	8,94	100%
REFERENCIA DO POÇO	SPORT CLUB - SETOR XXX	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		0,96	0,75	6,59	0,53	4,20	100%
REFERENCIA DO POÇO	SATA MARIA - SETOR XXXI	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		3,85	0,75	7,80	0,70	0,92	100%
REFERENCIA DO POÇO	PARQUE DAS JAQUEIRAS , CENTRAL PARK I E II E ELSHADAY - SETOR XXXII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,21	0,75	4,79	1,58	6,10	100%
REFERENCIA DO POÇO	SANTA RITA, CENTRO, BAIRRO CARÃO, PARAÍSO EXTREMO, PARQUE DOS SERVIDORES, PARAÍSO EXTREMOZ - SETOR XXXIII	RESIDUAL DE CLORO	TURBIDEZ	pH	COR	NITRATO	COLIFORMES TOTAIS
		VMP - 0,2 A 5,0 mg/l	VMP - <5,0 NTU	6,0 A 9,0	<15,0 UC	10,0 MH/L	95% DE AUSENCIA
MÉDIA DOS CONJUNTOS E LOTEAMENTOS		1,45	0,75	4,78	2,22	2,66	98%

